



Certified Water Testing

VELAP ID: 460012
 VA DW ID: 00240
 EPA ID: VA00050

1851 Rippon Boulevard
 Woodbridge, VA 22191
 703-393-2071

Average Point of Entry Analytical Report 2021

Point of Entry: 10298 Mill Street (East)

Test	MCL	Units	RL	Quarter 1	Quarter 2	Quarter 3	Quarter 4
Alkalinity		mg/L	20	40.4			
Aluminum		µg/L	25	BRL			
Antimony		µg/L	2	BRL			
Arsenic	10	µg/L	1	BRL			
Barium		µg/L	5	20.3			
Beryllium		µg/L	1	BRL			
Cadmium		µg/L	1	BRL			
Calcium		mg/L	2	17.4			
Chromium		µg/L	1	BRL			
Cl2, Total		mg/L	0.1	3.7			
Conductivity		umhos/cm	10	277.1			
Copper	1300	µg/L	1	BRL			
Hardness		mg/L	5	66.0			
Iron		µg/L	5	BRL			
Lead	15	µg/L	1	BRL			
Manganese		µg/L	5	6.0			
Nickel		µg/L	1	BRL			
NO2	1	mg/L	0.02	0.0			
NO2+NO3	10	mg/L	0.2	0.9			
NO3	10	mg/L	0.18	0.9			
o-PO4		mg/L	0.05	1.8			
Selenium	50	µg/L	1	BRL			
Silver		µg/L	5	BRL			
Sodium		mg/L	2	24.6			
Thallium		µg/L	1	BRL			
Total HAA	60	µg/L	1	1.7			
Total THM	80	µg/L	0.5	4.1			
Turbidity		NTU	0.1	BRL			
Zinc		µg/L	5	BRL			

MCL = Maximum Contamination Level
 mg/L = milligrams per liter, parts per million
 SU = Standard Units
 C = Celcius
 µg/L = micrograms per liter, parts per billion
 NTU = Nephelometric Turbidity Units
 umhos/cm = micromhos per centimeter
 RL = Reporting Limit
 BRL = Below Reporting Limit

Note: some of the data is averaged and based on multiple collections.

Report No. 210421102511



Certified Water Testing

VELAP ID: 460012
 VA DW ID: 00240
 EPA ID: VA00050

1851 Rippon Boulevard
 Woodbridge, VA 22191
 703-393-2071

Average Point of Entry Analytical Report 2021

Point of Entry: 14329 Glenkirk Road (West)

Test	MCL	Units	RL	Quarter 1	Quarter 2	Quarter 3	Quarter 4
Alkalinity		mg/L	20	30.3			
Aluminum		µg/L	25	BRL			
Antimony		µg/L	2	BRL			
Arsenic	10	µg/L	1	BRL			
Barium		µg/L	5	19.8			
Beryllium		µg/L	1	BRL			
Cadmium		µg/L	1	BRL			
Calcium		mg/L	2	10.6			
Chromium		µg/L	1	BRL			
Cl2, Total		mg/L	0.1	3.4			
Conductivity		umhos/cm	10	197.9			
Copper	1300	µg/L	1	BRL			
Hardness		mg/L	5	44.0			
Iron		µg/L	10	BRL			
Lead	15	µg/L	1	BRL			
Manganese		µg/L	5	BRL			
Nickel		µg/L	1	BRL			
NO2	1	mg/L	0.02	0.0			
NO2+NO3	10	mg/L	0.2	0.5			
NO3	10	mg/L	0.18	0.5			
o-PO4		mg/L	0.05	1.6			
Selenium	50	µg/L	1	BRL			
Silver		µg/L	5	BRL			
Sodium		mg/L	2	18.4			
Thallium		µg/L	1	BRL			
Total HAA	60	µg/L	1	15.3			
Total THM	80	µg/L	0.5	20.3			
Turbidity		NTU	0.1	0.1			
Zinc		µg/L	5	BRL			

MCL = Maximum Contamination Level
 mg/L = milligrams per liter, parts per million
 SU = Standard Units
 C = Celcius
 µg/L = micrograms per liter, parts per billion
 NTU = Nephelometric Turbidity Units
 umhos/cm = micromhos per centimeter
 RL = Reporting Limit
 BRL = Below Reporting Limit

Note: some of the data is averaged and based on multiple collections.

Report No. 210421102511



Certified Water Testing

VELAP ID: 460012 1851 Rippon Boulevard
 VA DW ID: 00240 Woodbridge, VA 22191
 EPA ID: VA00050 703-393-2071

Average Point of Entry Analytical Report 2021

Point of Entry: 8230 Patton Lane (West)

Test	MCL	Units	RL	Quarter 1	Quarter 2	Quarter 3	Quarter 4
Alkalinity		mg/L	20	107.7			
Aluminum		µg/L	25	BRL			
Antimony		µg/L	2	BRL			
Arsenic	10	µg/L	1	BRL			
Barium		µg/L	5	35.7			
Beryllium		µg/L	1	BRL			
Cadmium		µg/L	1	BRL			
Calcium		mg/L	2	46.9			
Chromium		µg/L	1	BRL			
Cl2, Total		mg/L	0.1	4.1			
Conductivity		umhos/cm	10	405.3			
Copper	1300	µg/L	1	BRL			
Hardness		mg/L	5	162.0			
Iron		µg/L	10	BRL			
Lead	15	µg/L	1	BRL			
Manganese		µg/L	5	BRL			
Nickel		µg/L	1	BRL			
NO2	1	mg/L	0.02	BRL			
NO2+NO3	10	mg/L	0.2	1.7			
NO3	10	mg/L	0.18	1.7			
o-PO4		mg/L	0.05	1.3			
Selenium	50	µg/L	1	BRL			
Silver		µg/L	5	BRL			
Sodium		mg/L	2	13.9			
Thallium		µg/L	1	BRL			
Total HAA	60	µg/L	1	BRL			
Total THM	80	µg/L	0.5	2.9			
Turbidity		NTU	0.1	BRL			
Zinc		µg/L	5	BRL			

MCL = Maximum Contamination Level
 mg/L = milligrams per liter, parts per million
 SU = Standard Units
 C = Celcius
 µg/L = micrograms per liter, parts per billion
 NTU = Nephelometric Turbidity Units
 umhos/cm = micromhos per centimeter
 RL = Reporting Limit
 BRL = Below Reporting Limit

Note: some of the data is averaged and based on multiple collections.

Report No. 210421102511